



## HAZARD REDUCTION CLEARANCE REQUIREMENTS CHECKLIST

---

- ✓ Provided a **30 ft.** clearance of all **non-ornamental** combustibles and vegetation around **all** structures. (This includes wood piles)
- ✓ Provided a total **100 ft. reduction** of all **non-ornamental** combustibles and vegetation around all structures.
- ✓ Remove trees and limbs within **10 ft.** of stovepipe and chimney outlets.
- ✓ Remove any dead limbs that overhang or are adjacent to structures.
- ✓ Clear roof of all combustible vegetation, including leaves and pine needles.
- ✓ Provide a **10 ft.** clearance of all combustible material around LPG and fuel tanks.
- ✓ Provide a minimum **10 ft.** clearance around all property lines **that encroach on the 100 foot defensible space of adjacent structures.**
- ✓ All **non-ornamental** trees should be limbed within **6 ft.** from the ground and dead limbs removed. (Although we can advise it, they are not currently required to completely remove dead trees!)
- ✓ Provide reduction of excessive accumulations of fuel that can be deemed a fire hazard.

**\*\*If issues on the property do not fall within one of the above categories, the property **cannot** be cited.\*\***