Office of the Fire Marshal
Kern County Fire Department

Fire Prevention
2820 M St. • Bakersfield, CA 93301 • www.kerncountyfire.org
Telephone 661-391-3310 • FAX 661-636-0466/67 • TTY Relay 800-735-2929

Christmas Tree Lots

Permits are required for the sale of Christmas trees. An inspection will be conducted to review the following:

- A minimum of one 2A10BC fire extinguisher for every 50' of travel within the tree lot.
- Maintain a minimum clearance of ten feet between trees and any building or structures. Trees may not be stored or displayed beneath any overhanging portion of a building.
- Maintain a minimum aisle clearance of 44" between rows of trees (35" between rows of trees and fences.
- Provide fire department access to all portions of the lot or buildings on the lot that are greater than 150' from access roads. Required fire lanes must be a minimum of 20' wide.
- Access gates to tree lots must remain open at all times during business hours.
- All electrical installations (lighting, etc.) must meet applicable codes.

Additional Requirements: _____

_____

Mailing Address:
Kern County Fire Department
2820 M St.
Bakersfield, CA 93301

11/17